



Stationary Power

Max Firmware Rev. L Release Notes

Installation

Unzip the MaxUpdate.zip, you should see an Update Files folder.

Open the Update Files folder and extract the 4 files; FIRM_1.MT1, FIRM_2.MT1, EEPROM.MT1 and FLASH.MT1 onto an empty flash drive.

Plug the flash drive into Max USB Port.

On the Max, from the MAIN menu, select CQ SYNC, UPDATE.

After Installation, from the MAIN menu select REPORTS then ABOUT.

The Code Versions; CPU FW, DSP FW, EEPROM, and FLASH should all be Rev. L.

Product Updates

- Better operation in noisy UPS installations
- Import data file larger than 512 KB
- Export data file larger than 512KB
- Export data with missing PLANTS and STRINGS
- Low internal battery warning message
- Reference Developer